

ADDENDUM NO. 02

PROJECT: Coddington Court – New Entrance Doors on Brick Buildings (20 doors)

DATE: January 31th, 2025

TO ALL BIDDERS OF RECORD:

This Addendum serves to modify, amend, and supplement a designated section of the INVITATION FOR BID pertaining to the project titled " **Coddington Court – New Entrance Doors on Brick Buildings (20 doors)**," dated Month, Day, Year. It is hereby incorporated by reference and shall hold the same binding authority as if fully integrated into the original document. The Bidder is tasked with incorporating the information contained within this Addendum No. 1 into their bid submission documents. Furthermore, it is incumbent upon them to inform all subcontractors and suppliers intended for various aspects of the project of any alterations or adjustments outlined within this Addendum. Failure to acknowledge the contents of this Addendum will preclude any claims for additional compensation.

A. This Addendum forms a part of the Contract Documents.

B. This Addendum includes:

- a. Correction to RFI and Pre-Bid meeting Questions /clarifications and Answers

Questions /Clarifications and answers:

- a. Clarification on "heavy Duty" for door components:

PUSH BAR:	Grade 1 stainless steel	<ul style="list-style-type: none"> • Sargent 2020 88 series • VonDuprin 99 series • <u>Or equal</u>
------------------	-------------------------	--

NOTICE TO ALL CONTRACTORS

Failure to acknowledge receipt of this addendum on the bid form may, at the sole discretion of the Owner, serve as justification for bid rejection.

END OF ADDENDUM NO.2

www.provhousing.org